

Our Ref: S165372 & S165411

31st March 2021



Chris Penston & Mark Richards
FabSpeed UK Limited
Skelmanthorpe Business Park
Saville Road
Skelmanthorpe
Huddersfield
West Yorkshire
HD8 9ED

Bucknalls Lane
Watford
Herts WD25 9BA
T +44 (0) 1923 665300
E clientservices@bba.star.co.uk
W www.bbacerts.co.uk

To whom it may concern

Re: BBA Assessment of Life Arch

The BBA is carrying out a full assessment of FabSpeed's Lite Arch, a cement particle board SIP product clad with adhesively fixed brick slips for use as a decorative brick slip clad arch over openings in low rise buildings. The arch is to be supported by a load bearing steel lintel below.

This is currently under two programmes of work but will be combined following the merging of Fab-lite and Litespeed (S165372 & S165411, respectively).

It is assembled by FabSpeed using prefabricated sip panel units supplied by SIP Building Systems, which are being assessed under the Stage 3 BBA reference S165416.

Following the successful completion of the durability testing programme, the BBA has assessed the data and can confirm that the requirements for 60-year durability for lightweight arch products have been met.

It is expected that the full certification will be issued by 30/6/21 subject to the assessment process.

The assessment is not yet complete and no conclusions can be drawn beyond the statement regarding 60-year durability. Should the outcome be satisfactory, a draft BBA Certificate will be presented to the BBA's Chief executive for permission to issue in due course.

Yours sincerely

Beena Tanna
Client Engagement Manager

Product Approval

Installer Approval

Test Services

Management Systems